

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7271-0559:0146 Page 1 of 1

CATEGORY: 7271 -- SMOKE DETECTOR-SYSTEM TYPE-IONIZATION

LISTEE: SILENT KNIGHT SECURITY 7550 Meridian Circle, Maple Grove, MN 55369-4927
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Models IDP-ION and SK-ION* ionization smoke detectors. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as an ionization smoke detectors for use with listee's listed Model IDP-6AB base (CSFM Listing No. 7300-0559:159) and separately listed compatible fire alarm control units. Model IDP-ION and SK-ION* are suitable for open area protection at air velocities up to 1200 fpm.

XLF: 7271-0028:0201

*Rev. 07-14-09 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division