

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-0559:0147

Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: SILENT KNIGHT SECURITY 7550 Meridian Circle, Maple Grove, MN 55369-4927
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Models IDP-HEAT and SK-HEAT* (fixed temperature), IDP-HEAT-ROR, IDP-HEAT-HT, SK-HEAT-ROR*, and SK-HEAT-HT* (fixed temperature with Rate-of-Rise) electronic heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 135°F fixed temperature for Models IDP-HEAT, IDP-HEAT-ROR, SK-HEAT* and SK-HEAT-ROR*
190°F fixed temperature for Model IDP-HEAT-HT and SK-HEAT-HT

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical ratings, and UL label.

APPROVAL: Listed as heat detectors for use with *listee's separately listed compatible base and fire alarm control units. Refer to listee's Installation Instructions Manual for details.

XLF: 7270-0028:0196

*Rev. 07-14-09 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division