

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0559:0167

Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: SILENT KNIGHT SECURITY 7550 Meridian Circle, Maple Grove, MN 55369-4927
Contact: Michael McIsaac (763) 493-6400 Fax (763) 391-5464
Email: mike.mcisaac@honeywell.com

DESIGN: Models IFP-FFT and SK-FFT firefighters phone system. Refer to listee's data sheet for detailed product description and operational considerations. System components:

FFT24; Expander Board
FFT-BGK; Break Glass Kit for FFT-STSR/STSS
FFT-FPJ; Phone Jack
FFT-HSC; Cabinet
FFT-RHS; Fire Fighter Remote Handset
FFT-STSR; Single Telephone Mounting Station (Recessed)
FFT-STSS; Single Telephone Mounting Station (Surface Mount)
IDP-ISO; Fault Isolation Module
IDP-MINIMON; Minimonitor Module
SK-ISO; Fault Isolation Module
SK-MINIMON; Minimonitor Module

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, and UL label.

APPROVAL: Listed as fire alarm accessory devices when used in conjunction with separately listed compatible control unit.

06-15-11 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2011**

Listing Expires **June 30, 2012**

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division