

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0559:0165

Page 1 of 1

CATEGORY: Fire Alarm Control Unit (Commercial)

LISTEE: SILENT KNIGHT SECURITY, 7550 Meridian Circle, Maple Grove, MN, 55369-4927
Contact: Michael McIsaac (763) 463-4144 Fax (763) 493-6475
Email: mike.mcisaac@honeywell.com

DESIGN: Models 5600, 5600HV, IFP-25 and IFP-25HV Fire Alarm Control Units. Automatic, manual, waterflow, sprinkler supervisory, local, remote station (PPU), central station (PPU) services. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

5220	Direct Connect Module
IPDACT2UD	IP DACT
HFS-MR	Reverse Polarity

RATING: 120 VAC or 230 VAC Primary, 24 VDC Secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as commercial fire alarm control unit for use with separately listed initiating and indicating devices. Refer to listee's Installation Instruction Manual for details.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition and meets the requirements of UL Standard 864, 9th Edition.

04-06-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **April 06, 2010**

Listing Expires **June 30, 2010**

Authorized By: **FRANCIS MATEO**, Program Coordinator
Fire Engineering Division