

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7270-0559:147

Page 1 of 1

**CATEGORY:** Heat Detector

**LISTEE:** Silent Knight Security, 7550 Meridan Circle, Maple Grove, MN 55369  
Contact: Mike McIsaac (763) 493-6424 FAX (763) 391-5464

**DESIGN:** Models IDP-Heat (fixed temperature), IDP-Heat-ROR and IDP-Heat-HT (fixed temperature with Rate-of-Rise) electronic heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 135<sup>0</sup> F fixed temperature for Models IDP-Heat and IDP-Heat-ROR  
190<sup>0</sup> F fixed temperature for Model IDP-Heat-HT

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL label.

**APPROVAL:** Listed as heat detectors for use with \*listee's separately listed compatible base and fire alarm control units. Refer to listee's Installation Instructions Manual for details.

**XL:** 7270-0028:196

05-26-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

*Listing Expires June 30, 2009*

Authorized By: **BEN HO, Chief**  
*Fire Engineering Division*