

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7271-0559:146 Page 1 of 1

**CATEGORY:** Ionization Smoke Detector

**LISTEE:** Silent Knight Security, 7550 Meridan Circle, Maple Grove, MN 55369  
Contact: Mike McIsaac (763) 493-6424 FAX (763) 391-5464

**DESIGN:** Model IDP-ION ionization smoke detector. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as an ionization smoke detectors for use with listee's listed Model IDP-6AB base (CSFM Listing No. 7300-0559:XXX Pending) and separately listed compatible fire alarm control units. Model IDP-ION is suitable for open area protection at air velocities up to 1200 fpm.

**XL:** 7271-0028:201

05-25-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2009**

*Listing Expires June 30, 2010*

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division