

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0559:153 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Silent Knight, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: Mike Mclsaac (763) 493-6424 FAX (763) 391-5464

DESIGN: Model IDP-ISO Fault Isolator Module. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Module = 15-32 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLf: 7300-1653:192

07-20-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2008**

Listing Expires June 30, 2009

Authorized By: **BEN HO, Chief**
Fire Engineering Division