

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0559:155 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369
Contact: Mike McIsaac (763) 493-6424 FAX (763) 391-5464
mike.mcisaac@honeywell.com

DESIGN: Models IDP-Relay-6, SK-Relay-6*, relay module, IDP-Control-6, SK-Control-6*, supervising control module, IDP-Monitor-10, SK-Mon-10*, input monitor module, IDP-Zone-6, SK-Zone-6* six zone interface module, IDP-Monitor*, IDP-Minimon*, IDP-Zone*, SK-Monitor*, SK-Minimon*, SK-Zone* monitor modules, IDP-Control*, IDP-Relay*, SK-Control*, SK-Relay*, control modules, IDP-Monitor-2*, and SK-Monitor-2*, dual monitor modules. All devices are intended to be connected between the signaling line circuit of a compatible fire alarm control panel. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 16-33 VDC Primary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product number and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed compatible fire alarm control units.

NOTE: If an external power supply is used for Model SK-Zone-6* and IDP-Zone-6, the negative of the external power supply is referenced to the negative of the auxiliary supply of the compatible control panel. This is done in order to detect ground faults on the initiating circuit.

XL: 7300-0028:219

*Rev. 07-14-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JULY 17, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division