



FIRE DEPARTMENT

9 METROTECH CENTER

BROOKLYN, N.Y. 11201-3857

CERTIFICATE OF APPROVAL # 6057 THIS CERTIFICATE IS REVOCABLE, NOT TRANSFERABLE AND EXPIRES ON July 9, 2013

By order of Fire Commissioner Salvatore Cassano, and pursuant to Section FC 112 of the New York City New Fire Code, the following equipment or system is accepted for use provided the conditions as outlined below are in full compliance.

Manufacturer:	Honeywell International Inc.
Trade Name:	Silent Knight
Product:	Fire Alarm Control Panel IntelliKnight
Basic Model Number(s):	5600, IPF-25
Pertinent Code Section(s):	Section FC 901 of the New York City Fire Code
Test(s) Standards(s):	UL 864 9 th Edition
Laboratory:	Intertek Testing Services NA Inc. (ETL)
Test Report(s):	Report No. 3189837NYM-001a; Issued 25-01-2010
Description:	The IntelliKnight 5600 is a 25-point class leading single loop addressable fire alarm control/communicator system. IntelliKnight 5600 provides you with the revolutionary value and performance of addressable sensing technology combined with exclusive, built-in digital communication that includes an easy to use interface. With code wheel addressable detectors/modules and JumpStart™ feature the 5600 can be Life Safety operational without a single programming tool.

Conditions of Approval:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Construction Codes, specifically Building Code Chapter 9 & Appendix Q Section BC Q106, and New York City Electrical Code. Further, the installation shall be in accordance applicable provisions of New York City Fire Code and IRCNY §4000-06, manufacturer's recommendations and UL Standard 864.

Expires on July 8, 2013
COA #6057 for Silent Knight
F.P. Index#: 1005057
FPIMS#: 30093025
July 9, 2010
Page 2 of 3

2. When used with a central office control communicator or a transmitter (DACT), the installation and operation of the equipment and devices shall comply with 3RCNY R901-01. It shall have the capability of transmitting separate and distinct signals to indicate manual pull station alarm, automatic detection alarm, sprinkler waterflow alarm, supervisory signal indications, and trouble indications.
3. The connection of security/burglar devices and equipment to the fire alarm control unit is prohibited. A sign must be provided to indicate the same.
4. The above referenced Fire Alarm Control Panels shall be used only with listed fire alarm equipment and devices, with which the compatibility has been determined by ETL listing report
5. Intertek Testing Services NA Inc. (ETL) listing requirements and limitations shall be complied with.
6. Only enclosures painted red in color shall be used.
7. Certificate of Approval number shall be plainly and permanently stamped or otherwise fixed upon each product by the applicant.
8. The Fire Department's conditions of approval shall be enumerated in the installation manuals and brochures that will be provided to all New York City buyers and users.
9. Fire Department Certificate of Approval does not constitute an endorsement or recommendation of your product by the Fire Department, but is a certification that your product is acceptable as of the date of issuance.
10. The Fire Department reserves the right to withdraw this approval at any time in the event there is a reasonable doubt that the product does not operate or perform as required by code, the conditions of this resolution or as represented in your application.
11. As the manufacturer of this product, you should be aware that any end user who fails to comply with the condition as outlined in the approval would be subject to enforcement action, which may include fines and imprisonment.

Any change in company name or ownership, product name, design or model number of any product included on this certificate must be immediately reported to this Department in writing.

When responding to this Department regarding this subject matter, kindly refer to F.P. Index # 1005057 and to Igor Chouchereba attention, 9 MetroTech Center #1S-43-K, phone (718) 999-1997.

Expires on July 8, 2013
COA #6057 for Silent Knight
F.P. Index#: 1005057
FPIMS#: 30093025
July 9, 2010
Page 3 of 3

Very truly yours,

A handwritten signature in black ink, appearing to read 'Shaji K. Joseph', written in a cursive style.

Shaji K. Joseph
Chief Examiner
Technology Management

c: Tamara Saakian, P.E., Director of Engineering.

SJ: IC/1005057